

HERS WATER VERIFICATION OF EXISTING CONDITIONS

01	02	03	04	05	06	07
Indoor Air Quality (IAQ) Fans - Verified and Aired						
Name	Airflow (CFM)	Fan Efficiency (W/CFM)	IAQ Fan Type	Includes Heat/Energy Recovery?	IAQ Recovery Effectiveness - MIRAQ Recovery Effectiveness - SRE	IAQ Recovery Effectiveness - ASRE
Dwelling Unit ID	30	0.23333	Balanced	Yes	88	88

CaCERTS, Inc.
 HERS PROVIDER

Registration Number: 223-P191861806A-000-000-000000-0000
 Registration Date/Time: 2023-11-02 10:31:33
 HERS Provider: CaCERTS, Inc.
 Report Generated: 2023-11-22 10:17:40

DOCUMENTATION AUTHORITY'S DECLARATION STATEMENT

I, certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Nicholas Bignardi
 Signature Date: 2023-11-22 10:27:49

Company: FRI Energy Consultants, LLC
 Address: 5770 Winfield Boulevard #15
 San Jose, CA 95123
 Phone: 408-866-1620

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I, certify the following under penalty of perjury, under the laws of the State of California:

1. I am a duly authorized person or a duly authorized representative of the building designer identified on this Certificate of Compliance.

2. I certify that the energy features and performance specifications identified on this Certificate of Compliance conform to the requirements of Title 24, Part 3 and Part 6 of the California Code of Regulations.

3. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.

Responsible Designer Name: Nicholas Bignardi
 Signature Date: 2023-11-22 10:31:33

Company: FRI Energy Consultants, LLC
 Address: 5770 Winfield Boulevard #15
 San Jose, CA 95123
 Phone: 408-866-1620

Digitally signed by CaCERTS, Inc. This digital signature is provided in order to secure the content of this registered document, and in no way implies Registration Provider responsibility for the accuracy of the information.

Registration Number: 223-P191861806A-000-000-000000-0000
 Registration Date/Time: 2023-11-02 10:31:33
 HERS Provider: CaCERTS, Inc.
 Report Generated: 2023-11-22 10:17:40

2022 Single-Family Residential Mandatory Requirements Summary

- NOTE:** Single-family residential buildings subject to the Energy Codes must comply with all applicable mandatory measures, regardless of the compliance approach used. Review the respective section for more information.
- Building Envelope:**
- § 110.6(a): **Air Leakage, Manufactured fenestration, exterior doors, and exterior pet doors** must limit air leakage to 0.3 CFM per square foot or less when tested per NFRG-400, ASTM E283, or AAMA/WOMA/CSA 1011.1.2/2440-2011.
 - § 110.6(a)(5): **Labeling.** Fenestration products and exterior doors must have a label meeting the requirements of § 110.11(a).
 - § 110.6(b): **Field fabricated exterior doors and fenestration products** must use U-factors and solar heat gain coefficient (SHGC) values from Tables 110.6-A, 110.6-B, or J44.1 for exterior doors. They must be caulked and/or weather-stripped.
 - § 110.7: **Air Leakage.** All joints, penetrations, and other openings in the building envelope that are potential sources of air leakage must be caulked, gasketed, or weather stripped.
 - § 110.8(a): **Insulation Certification by Manufacturers.** Insulation must be certified by the Department of Consumer Affairs, Bureau of Household Goods and Services (BHSG).
 - § 110.8(b): **Insulation Requirements for Heated Slab Floors.** Heated slab floors must be insulated per the requirements of § 110.8(b).
 - § 110.8(c): **Roofing Products Solar Reflectance and Thermal Emittance.** The thermal emittance and aged solar reflectance values of the roofing material must meet the requirements of § 110.8(c) and be labeled per § 110.113 when the installation of a cool roof is specified on the CFI-R.
 - § 110.8(d): **Radiant Barrier.** When required, radiant barriers must have an emittance of 0.05 or less and be certified to the Department of Consumer Affairs.
 - § 150.0(a): **Roof Deck, Ceiling and Rafter Roof Insulation.** Roof decks in newly constructed attics in climate zones 4 and 8-16 area-weighted average U-factor must not exceed 0.164. Ceiling and rafter roofs minimum R-19 or area-weighted average U-factor of 0.034 or less. Attic access doors must have permanently attached insulation using adhesive or mechanical fasteners. The attic access must be gasketed to prevent air leakage. Insulation must be installed in direct contact with a roof or ceiling which is sealed to limit infiltration and exfiltration, as specified in § 110.7, including but not limited to placing insulation either above or below the roof deck or on top of a drywall ceiling.
 - § 150.0(b): **Loose-fill Insulation.** Loose fill insulation must meet the manufacturer's required density for the labeled R-value.
 - § 150.0(c): **Wall Insulation.** Minimum R-13 insulation in 2x4 inch wood framing wall or have a U-factor of 0.102 or less, or R-20 in 2x6 inch wood framing or have a U-factor of 0.071 or less. Opaque non-framed assemblies must have an overall assembly U-factor not exceeding 0.102. Masonry walls must meet Tables 150.1-A or B.
 - § 150.0(d): **Raised-floor Insulation.** Minimum R-19 insulation in raised wood framed floor or 0.037 maximum U-factor.
 - § 150.0(f): **Slab Edge Insulation.** Slab edge insulation must meet all of the following: have a water absorption rate, for the insulation material alone without facings, no greater than 0.3 percent; have a water vapor permeance no greater than 2.0 perm per inch; be protected from physical damage and UV light deterioration; and, when installed as part of a heated slab floor, meet the requirements of § 110.8(g).
 - § 150.0(g)(1): **Vapor Retarder.** In climate zones 1 through 16, the earth floor or unvented crawl space must be covered with a Class I or Class II vapor retarder. This requirement also applies to controlled ventilation crawl space for buildings complying with the exception to § 150.0(d).
 - § 150.0(g)(2): **Vapor Retarder.** In climate zones 14 and 16, a Class I or Class II vapor retarder must be installed on the conditioned space side of all insulation in all exterior walls, vented attics, and unvented attics with air-permeable insulation.
 - § 150.0(i): **Fenestration Products.** Fenestration, including skylights, separating conditioned space from unconditioned space or outdoors must have a maximum U-factor of 0.45, or area-weighted average U-factor of fenestration must not exceed 0.45.
- Fireplaces, Decorative Gas Appliances, and Gas Log:**
- § 110.5(a): **Pilot Light.** Continuously burning pilot lights are not allowed for indoor and outdoor fireplaces.
 - § 150.0(i): **Closable Doors.** Masonry or factory-built fireplaces must have a closable metal or glass door covering the entire opening of the firebox.
 - § 150.0(j): **Combustion Intake.** Masonry or factory-built fireplaces must have a combustion outside air intake, which is at least six square inches in area and is equipped with a readily accessible, operable, and light-tighting damper or combustion-air control device.
 - § 150.0(k): **Flue Damper.** Masonry or factory-built fireplaces must have a flue damper with a readily accessible control.
- Space Conditioning, Water Heating, and Plumbing System:**
- § 110.0.4 § 110.3: **Certification, Heating, ventilation, and air conditioning (HVAC) equipment, water heaters, showerheads, faucets, and all other regulated appliances** must be certified by the manufacturer to the California Energy Commission.
 - § 110.2(a): **HVAC Efficiency.** Equipment must meet the applicable efficiency requirements in Table 110.2.A through Table 110.2.N.
 - § 110.2(b): **Controls for Heat Pumps with Supplementary Electric Resistance Heaters.** Heat pumps with supplementary electric resistance heaters must have controls that prevent supplementary heater operation when the heating load can be met by the heat pump alone; and in which the cut-on temperature for compression heating is higher than the cut-on temperature for supplementary heating; and the cut-off temperature for compression heating is higher than the cut-off temperature for supplementary heating.
 - § 110.2(c): **Thermostats.** All heating or cooling systems not controlled by a central energy management control system (EMCS) must have a setback thermostat.
 - § 110.3(a): **Insulation.** Unfired service water heater storage tanks and solar water-heating backup tanks must have adequate insulation, or tank surface heat loss rating.
 - § 110.3(b): **Isolation Valves.** Instantaneous water heaters with an input rating greater than 6.8 kBtu per hour (2 kW) must have isolation valves with hose bibbs or other fittings on both cold and hot water lines to allow for flushing the water heater when the valves are closed.

5/6/22

2022 Single-Family Residential Mandatory Requirements Summary

- § 110.5: **Pilot Lights.** Continuously burning pilot lights are prohibited for natural gas, fan-type central furnaces; household cooking appliances (except appliances without an electrical supply voltage connection with pilot lights that consume less than 150 Btu per hour); and pool and spa heaters.
 - § 150.0(h): **Building Cooling and Heating Loads.** Heating and/or cooling loads are calculated in accordance with the ASHRAE Handbook, Equipment Volume, Applications Volume, and Fundamentals Volume; the SMACNA Residential Comfort System Installation Standards Manual; or the ACCA Manual J using design conditions specified in § 150.0(h)(2).
 - § 150.0(h)(3A): **Clearances.** Air conditioner and heat pump outdoor condensing units must have a clearance of at least five feet from the outlet of any duct.
 - § 150.0(h)(3B): **Liquid Line Drier.** Air conditioners and heat pump systems must be equipped with liquid line filter driers if required, as specified by the manufacturer's instructions.
 - § 150.0(i): **Water Piping, Solar Water-heating System Piping, and Space Conditioning System Line Insulation.** All domestic hot water piping must be insulated as specified in § 609.11 of the California Plumbing Code.
 - § 150.0(j): **Insulation Protection.** Piping insulation must be protected from damage, including that due to sunlight, moisture, equipment maintenance, and wind as required by § 110.2(b). Insulation exposed to weather must be water resistant and protected from UV light (no adhesive tapes). Insulation covering chilled water piping and refrigerant suction piping located outside the conditioned space must include, or be protected by, a Class I or Class II vapor retarder. Pipe insulation buried below grade must be installed in a waterproof and non-crushable casing or sleeve.
 - § 150.0(k): **Gas or Propane Water Heating Systems.** Systems using gas or propane water heaters to serve individual dwelling units must designate a space at least 2.5' x 2.5' x 7' suitable for the future installation of a heat pump water heater, and meet electrical and plumbing requirements, based on the distance between this designated space and the water heater location, and a condensate drain no more than 2' higher than the base of the water heater.
 - § 150.0(l): **Solar Water-heating Systems.** Solar water-heating systems and collectors must be certified and rated by the Solar Rating and Certification Corporation (SRCC), the International Association of Plumbing and Mechanical Officials, Research and Testing (IAPMO R&T), or by a listing agency that is approved by the executive director.
- Ducts and Fans:**
- § 110.8(i)(3): **Ducts.** Insulation installed on an existing space-conditioning duct must comply with § 604.0 of the California Mechanical Code (CMC), if a contractor installs the insulation, the contractor must certify to the customer, in writing, that the insulation meets this requirement.
 - § 150.0(m): **CMC Compliance.** All air-distribution system ducts and plenums must meet CMC §§ 601.0-605.0 and ANSI/SMACNA-006-2006 HVAC Duct Construction Standards Metal and Flexible 3rd Edition. Portions of supply-air and return-air ducts and plenums must be insulated to R-6.0 or higher; ducts located entirely in conditioned space as confirmed through field verification and diagnostic testing (RA3.1, 4.3, 8) do not require insulation. Connections of metal ducts and inner core of flexible ducts must be mechanically fastened. Openings must be sealed with mastic, tape, or other duct-closure system that meets the applicable UL requirements, or aerosol sealant that meets UL 723. The combination of mastic and either mesh or tape must be used to seal openings greater than 1/4". If mastic or tape is used, Building cavities, air handler support platforms, and plenums designed or constructed with materials other than sealed sheet metal, duct board or flexible duct must not be used to convey conditioned air. Building cavities and support platforms may contain ducts, ducts installed in these spaces must not be compressed.
 - § 150.0(m)(2): **Factory-Fabricated Duct Systems.** Factory-fabricated duct systems must comply with applicable requirements for duct construction, connections, and closures; joints and seams of duct systems and their components must not be sealed with cloth back rubber adhesive duct tapes unless such tape is used in combination with mastic and draw bands.
 - § 150.0(m)(3): **Field-Fabricated Duct Systems.** Field-fabricated duct systems must comply with applicable requirements for pressure-sensitive tapes, mastics, sealants, and other requirements specified for duct construction.
 - § 150.0(m)(7): **Backdraft Damper.** Fan systems that exchange air between the conditioned space and outdoors must have backdraft or automatic dampers.
 - § 150.0(m)(8): **Gravity Ventilation Dampers.** Gravity ventilation systems serving conditioned space must have either automatic or readily accessible, manually operated dampers in all openings to the outside, except combustion inlet and outdoor air openings and elevator shaft vents.
 - § 150.0(m)(9): **Protection of Insulation.** Insulation must be protected from damage due to sunlight, moisture, equipment maintenance, and wind. Insulation exposed to weather must be suitable for outdoor service (e.g., protected by aluminum, sheet metal, painted canvas, or plastic cover). Cellular foam insulation must be protected as above or painted with a water resistant and solar radiation-resistant coating.
 - § 150.0(m)(10): **Porous Inner Core Flex Duct.** Porous inner cores of flex ducts must have a non-porous layer or air barrier between the inner core and outer vapor barrier.
 - § 150.0(m)(11): **Duct System Sealing and Leakage Test.** When space conditioning systems use forced air duct systems to supply conditioned air to an occupiable space, the ducts must be sealed and duct leakage tested, as confirmed through field verification and diagnostic testing, in accordance with Reference Residential Appendix RA3.1.
 - § 150.0(m)(12): **Air Filtration.** Space conditioning systems with ducts exceeding 10 feet and the supply side of ventilation systems must have MERV 13 or equivalent filters. Filters for space conditioning systems must have a two inch depth or can be one inch if sized per Equation 150.0-A. Clean filter pressure drop and labeling must meet the requirements in § 150.0(m)(12). Filters must be accessible for regular service. Filter racks or grilles must use gaskets, sealing, or other means to close gaps around the inserted filters to and prevents air from bypassing the filter.

5/6/22

2022 Single-Family Residential Mandatory Requirements Summary

- § 150.0(m)(13): **Space Conditioning System Airflow Rate and Fan Efficacy.** Space conditioning systems that use ducts to supply cooling must have a note for the placement of a static pressure probe, or a permanently installed static pressure probe in the supply plenum. Airflow must be ≥ 350 CFM per ton of nominal cooling capacity, and an air-handling unit fan efficacy ≥ 0.45 watts per CFM for gas furnace air handlers and ≤ 0.58 watts per CFM for others. Small duct high velocity systems must provide an airflow ≥ 250 CFM per ton of nominal cooling capacity, and an air-handling unit fan efficacy ≥ 0.62 watts per CFM. Field verification testing is required in accordance with Reference Residential Appendix RA3.3.
- Ventilation and Indoor Air Quality:**
- § 150.0(o): **Requirements for Ventilation and Indoor Air Quality.** All dwelling units must meet the requirements of ASHRAE Standard 62.2. Ventilation and Acceptable Indoor Air Quality in Residential Buildings subject to the amendments specified in § 150.0(o)(1).
 - § 150.0(o)(1B): **Central Fan Integrated (CFI) Ventilation Systems.** Continuous operation of CFI air handlers is not allowed to provide the whole-dwelling unit ventilation airflow required per § 150.0(o)(1C). A motorized damper(s) must be installed on the ventilation duct(s) that prevents all airflow through the space conditioning duct system when the damper(s) is closed and/or controlled per § 150.0(o)(1B)(iv). CFI ventilation systems must have controls that track outdoor air ventilation run time, and either open or close the motorized damper(s) for compliance with § 150.0(o)(1C).
 - § 150.0(o)(1C): **Whole-Dwelling Unit Mechanical Ventilation for Single-Family Detached and Townhouses.** Single-family detached dwelling units, and attached dwelling units not sharing ceilings or floors with other dwelling units, occupiable spaces, public garages, or commercial spaces must have mechanical ventilation airflow specified in § 150.0(o)(1C)(ii).
 - § 150.0(o)(1G): **Local Mechanical Exhaust.** Kitchens and bathrooms must have local mechanical exhaust; nonenclosed kitchens must have demand-controlled exhaust system meeting requirements of § 150.0(o)(1G)(ii) enclosed kitchens and bathrooms can use demand-controlled or continuous exhaust meeting § 150.0(o)(1G)(iv). Airflow must be measured by the installer per § 150.0(o)(1G)(v), and rated for sound per § 150.0(o)(1G)(vi).
 - § 150.0(o)(1H)(4): **Airflow Measurement and Sound Ratings of Whole-Dwelling Unit Ventilation Systems.** The airflow required per § 150.0(o)(1C) must be measured by using a flow hood, flow grid, or other airflow measuring device at the fan's inlet or outlet terminals/grilles per Reference Residential Appendix RA3.7. Whole-Dwelling Unit Ventilation systems must be rated for sound per ASHRAE 62.2 § 7.2 at no less than the minimum airflow rate required by § 150.0(o)(1C).
 - § 150.0(o)(2): **Field Verification and Diagnostic Testing.** Whole-Dwelling Unit ventilation airflow, vented range hood airflow and sound rating, and HRV and ERV fan efficacy must be verified in accordance with Reference Residential Appendix RA3.7. Vented range hoods must be verified per Reference Residential Appendix RA3.7.4.3 to confirm if it is rated by HVI or AHAM to comply with the airflow rates and sound requirements per § 150.0(o)(1G).
- Pool and Spa Systems and Equipment:**
- § 110.4(a): **Certification by Manufacturers.** Any pool or spa heating system or equipment must be certified to have all of the following: compliance with the Appliance Efficiency Regulations and listing in MAEDS; an on-off switch mounted outside of the heater that allows shutting off the heater without adjusting the thermostat setting; a permanent waterproof plate or card with operating instructions; and must not use electric resistance heating.
 - § 110.4(b): **Piping.** Any pool or spa heating system or equipment must be installed with at least 38 inches of pipe between the filter and the heater, or dedicated suction and return lines, or built-in bulkhead connections to allow for future solar heating.
 - § 110.4(b)(2): **Covers.** Outdoor pools or spas that have a heat pump or gas heater must have a cover.
 - § 110.4(b)(3): **Directional Inlets and Time Switches for Pools.** Pools must have directional inlets that adequately mix the pool water, and a time switch that will allow all pumps to be set or programmed to run only during off-peak electric demand periods.
 - § 110.5: **Pilot Light.** Natural gas pool and spa heaters must not have a continuously burning pilot light.
 - § 150.0(p): **Pool Systems and Equipment Installation.** Residential pool systems or equipment must meet the specified requirements for pump sizing, flow rate, piping, filters, and valves.
- Lighting:**
- § 110.9: **Lighting Controls and Components.** All lighting control devices and systems, ballasts, and luminaires must meet the applicable requirements of § 110.9.
 - § 150.0(k)(1A): **Luminaire Efficacy.** All installed luminaires must meet the requirements in Table 150.0-A, except lighting integral to exhaust fans, kitchen range hoods, built-in vanity mirrors, and garage door openers; navigation lighting less than 5 watts; and lighting integral to drawers, cabinets, and linen closets with an efficacy of at least 45 lumens per watt.
 - § 150.0(k)(1B): **Screen based luminaires.** Screen based luminaires must contain lamps that comply with Reference Joint Appendix JA8.
 - § 150.0(k)(1C): **Recessed Downlight Luminaires in Ceilings.** Luminaires recessed into ceilings must not contain screw based sockets, must be airtight, and must be sealed with a gasket or caul. California Electrical Code § 410.116 must also be met.
 - § 150.0(k)(1D): **Light Sources in Enclosed or Recessed Luminaires.** Lamps and other separable light sources that are not compliant with the JA8 elevated temperature requirements, including marking requirements, must not be installed in enclosed or recessed luminaires.
 - § 150.0(k)(1E): **Blank Electrical Boxes.** The number of electrical boxes that are more than five feet above the finished floor and do not contain a luminaire or other device shall be no more than the number of bedrooms. These boxes must be served by a dimmer, vacancy sensor control, low voltage wiring, or fan speed control.
 - § 150.0(k)(1F): **Lighting Integral to Exhaust Fans.** Lighting integral to exhaust fans (except when installed by the manufacturer in kitchen exhaust hoods) must meet the applicable requirements of § 150.0(k).

5/6/22

2022 Single-Family Residential Mandatory Requirements Summary

- § 150.0(k)(1G): **Screw based luminaires.** Screw based luminaires must contain lamps that comply with Reference Joint Appendix JA8.
 - § 150.0(k)(1H): **Light Sources in Enclosed or Recessed Luminaires.** Lamps and other separable light sources that are not compliant with the JA8 elevated temperature requirements, including marking requirements, must not be installed in enclosed or recessed luminaires.
 - § 150.0(k)(1): **Light Sources in Drawers, Cabinets, and Linen Closets.** Light sources internal to drawers, cabinets or linen closets are not required to comply with Table 150.0-A or be controlled by vacancy sensors provided that they are rated to consume no more than 5 watts of power, emit no more than 150 lumens, and are equipped with controls that automatically turn the lighting off when the drawer, cabinet or linen closet is closed.
 - § 150.0(k)(2A): **Interior Switches and Controls.** All forward phase cut dimmers used with LED light sources must comply with NEMA SSL 7A.
 - § 150.0(k)(2B): **Interior Switches and Controls.** Exhaust fans must be controlled separately from lighting systems.
 - § 150.0(k)(2A): **Accessible Controls.** Lighting must have readily accessible wall-mounted controls that allow the lighting to be manually turned on and off.
 - § 150.0(k)(2B): **Multiple Controls.** Controls must not bypass a dimmer, occupant sensor, or vacancy sensor function if the dimmer or sensor is installed to comply with § 150.0(k).
 - § 150.0(k)(2C): **Mandatory Requirements.** Lighting controls must comply with the applicable requirements of § 110.9.
 - § 150.0(k)(2D): **Energy Management Control Systems.** An energy management control system (EMCS) may be used to comply with dimming, occupancy, and control requirements if it provides the functionality of the specified control per § 110.9 and the physical controls specified in § 150.0(k)(2A).
 - § 150.0(k)(2E): **Automatic Shutoff Controls.** In bathrooms, garages, laundry rooms, utility rooms and walk-in closets, at least one installed luminaire must be controlled by an occupancy or vacancy sensor providing automatic-off functionality. Lighting inside drawers and cabinets with opaque fronts or doors must have controls that turn the light off when the drawer or door is closed.
 - § 150.0(k)(2F): **Dimmers.** Lighting in habitable spaces (e.g., living rooms, dining rooms, kitchens, and bedrooms) must have readily accessible wall-mounted dimming controls that allow the lighting to be manually adjusted up and down. Forward phase cut dimmers controlling LED light sources in these spaces must comply with NEMA SSL 7A.
 - § 150.0(k)(3A): **Residential Outdoor Lighting.** For single-family residential buildings, outdoor lighting permanently mounted to a residential building, or to other buildings on the same lot, must have a manual on/off switch and either a photocell and motion sensor or automatic time switch control) or an astronomical time clock. An energy management control system that provides the specified control functionality and meets all applicable requirements may be used to meet these requirements.
 - § 150.0(k)(4): **Internally illuminated address signs.** Internally illuminated address signs must either comply with § 140.8 or consume no more than 5 watts of power.
 - § 150.0(k)(5): **Residential Garages for Eight or More Vehicles.** Lighting for residential parking garages for eight or more vehicles must comply with the applicable requirements for nonresidential garages in §§ 110.9, 130.0, 130.1, 130.4, 140.6, and 141.0.
- Solar Readiness:**
- § 110.10(a)(1): **Single-Family Residences.** Single-family residences located in subdivisions with 10 or more single-family residences and where the application for a tentative subdivision map for the residences has been deemed complete and approved by the enforcement agency, which do not have a photovoltaic system installed, must comply with the requirements of § 110.10(b)-(e).
 - § 110.10(a)(2): **Minimum Solar Zone Area.** The solar zone must have a minimum total area as described below. The solar zone must comply with access, pathway, smoke venting, and spacing requirements as specified in Title 24, Part 9 or other parts of Title 24 or in any requirements adopted by a local jurisdiction. The solar zone total area must be comprised of areas that have no dimension less than 5 feet and are no less than 80 square feet each for buildings with roof areas less than or equal to 10,000 square feet or no less than 160 square feet each for buildings with roof areas greater than 10,000 square feet. For single-family residences, the solar zone must be located on the roof or overhang of the building and have a total area no less than 250 square feet.
 - § 110.10(b)(1): **Azimuth.** All sections of the solar zone located on steep-sloped roofs must have an azimuth between 90-300° of true north.
 - § 110.10(b)(3A): **Shading.** The solar zone must not contain any obstructions, including but not limited to: vents, chimneys, architectural features, and roof mounted equipment.
 - § 110.10(b)(3B): **Shading.** Any obstruction located on the roof or any other part of the building that projects above a solar zone must be located at least twice the horizontal distance of the height difference between the highest point of the obstruction and the horizontal projection of the nearest point of the solar zone, measured in the vertical plane.
 - § 110.10(b)(4): **Structural Design Loads on Construction Documents.** For areas of the roof designated as a solar zone, the structural design loads for roof dead load and roof live load must be clearly indicated on the construction documents.
 - § 110.10(c): **Interconnection Pathways.** The construction documents must indicate a location reserved for inverters and metering equipment and a pathway reserved for routing of conduit from the solar zone to the point of interconnection with the electrical service, and for single-family residences and central water-heating systems, a pathway reserved for routing plumbing from the solar zone to the water-heating system. Documentation. A copy of the construction documents or a comparable document indicating the information from § 110.10(b)-(c) must be provided to the occupant.
 - § 110.10(d): **Main Electrical Service Panel.** The main electrical service panel must have a minimum busbar rating of 200 amps.
 - § 110.10(e)(1): **Main Electrical Service Panel.** The main electrical service panel must have a reserved space to allow for the installation of a double pole circuit breaker for a future solar electric installation. The reserved space must be permanently marked as "For Future Solar Electric."
 - § 110.10(e)(2): **Electric and Energy Storage Ready.**

5/6/22

2022 Single-Family Residential Mandatory Requirements Summary

- § 150.0(k): **Energy Storage System (ESS) Ready.** All single-family residences must meet all of the following: Either ESS-ready interconnection equipment with backup up capacity of 60 amps or more and four or more ESS ready branch circuits, or a dedicated raceway from the main service to a subpanel that supplies the branch circuits in § 150.0(k); at least four branch circuits must be identified and have their source collocated at a single panelboard suitable to be supplied by the ESS, with one circuit supplying the refrigerator, one lighting circuit near the primary exit, and one circuit supplying a sleeping room receptacle outlet; main panelboard must have a minimum busbar rating of 225 amps; sufficient space must be reserved to allow future installation of a system isolation equipment transfer switch within 3' of the main panelboard; with raceways installed between the panelboard and the switch location to allow the connection of backup power source.
 - § 150.0(l): **Heat Pump Space Heater Ready.** Systems using gas or propane cooktop to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the furnace with circuit conductors rated at least 50 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
 - § 150.0(m): **Electric Cooktop Ready.** Systems using gas or propane cooktop to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the cooktop with circuit conductors rated at least 50 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
 - § 150.0(n): **Electric Clothes Dryer Ready.** Clothes dryer locations with gas or propane plumbing to serve individual dwelling units must include: A dedicated unobstructed 240V branch circuit wiring installed within 3' of the dryer location with circuit conductors rated at least 30 amps with the blank cover identified as "240V ready"; and a reserved main electrical service panel space to allow for the installation of a double pole circuit breaker permanently marked as "For Future 240V use."
- *Exceptions may apply.



5/6/22

HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name: Wallace-Jones Residence & ADU
 Date: 11/22/2023
 System Name: Main House HVAC
 Floor Area: 1,789

Number of Systems	HEATING SYSTEM	COIL COOLING PEAK			COIL HTG. PEAK	
		CFM	Sensible	Latent	CFM	Sensible
1	Heating System	734	15,273	577	708	27,093
1	Return Ventilated Lighting	0	0	0	0	0
1	Return Air Ducts	0	693	0	0	1,505
1	Return Fan	0	0	0	0	0
1	Ventilation	0	0	0	0	0
1	Supply Fan	0	0	0	0	0
1	Supply Air Ducts	0	693	0	0	1,505
1	TOTAL SYSTEM LOAD	734	16,558	577	708	30,103

Notes: values above given at ARI conditions TIME OF SYSTEM PEAK Aug 3 PM Jan 1 AM





HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name: Wallace-Jones Residence & ADU
 Date: 11/22/2023
 System Name: ADU Mini-Split
 Floor Area: 600

Number of Systems	HEATING SYSTEM	COIL COOLING PEAK			COIL HTG. PEAK	
		CFM	Sensible	Latent	CFM	Sensible
1	Heating System	200	4,319	193	178	7,029
1	Return Ventilated Lighting	0	0	0	0	0
1	Return Air Ducts	0	0	0	0	0
1	Return Fan	0	0	0	0	0
1	Ventilation	0	0	0	0	0
1	Supply Fan	0	0	0	0	0
1	Supply Air Ducts	0	0	0	0	0
1	TOTAL SYSTEM LOAD	200	4,319	193	178	7,029

Notes: values above given at ARI conditions TIME OF SYSTEM PEAK Aug 3 PM Jan 1 AM



WALLACE-JONES RESIDENCE
 & ADU
 57